



EGTEI Methodology

Work to update costs for LCP

SO₂, NO_x and PM abatement techniques

Second meeting
31 January 2012



Agenda

- ◆ Information Gothenburg Protocol revision, NEC directive revision, LCP BREF process
- ◆ Outcomes of the kick off meeting – objectives
- ◆ General hypothesis
- ◆ Co-firing of biomass
- ◆ Investments and operating costs for SO₂ reduction techniques
- ◆ Investments and operating costs for NO_x reduction techniques
- ◆ Investments and operating costs for PM reduction techniques
- ◆ Collection of investments covering the techniques considered by the group and thermal capacities > 50 MWth
- ◆ Other issues

Agenda

- ◆ Information Gothenburg Protocol revision, NEC directive revision, LCP BREF process
- ◆ Outcomes of the kick off meeting – objectives
- ◆ General hypothesis
- ◆ Co-firing of biomass
- ◆ Investment and operating costs for SO₂ reduction techniques
- ◆ Investment and operating costs for NO_x reduction techniques
- ◆ Investments and operating costs for PM reduction techniques
- ◆ Collection of investments covering the techniques considered by the group and thermal capacities > 50 MWth
- ◆ Other issues

3

Gothenburg Protocol

- ◆ Negotiations could be finalised in April 2012, if not in September 2012
- ◆ Introduction of PM_{2.5}
- ◆ Set of ELVs which could be based on option 2 (for combustion installation, similar to IED)
- ◆ No absolute ceilings but percentage of reduction of emissions, with 2005 as reference year
- ◆ Flexibility mechanisms introduced to enable the addition of new sources, unexpected changes in emission factors, average emissions over 3 years,
- ◆ Reductions announced

% / 2005	EU	USA	CH
SO ₂	-55	-58	-20
NO _x	-40	-47	-49
NH ₃	-5		-13
VOC	-35	-24	-32
PM	-20	-24	-26

Revision of the NEC Directive

- ◆ NEC directive in revision
- ◆ Directive project expected in 2013
- ◆ 2025 or 2030 as target year possible
- ◆ Work programme for the determination of emissions in 2020 - 2030
 - February:
 - Report and on-line access to Final EC4MACS baseline emission scenario (GAINS/IIASA)
 - March-September:
 - Bilateral consultations MS experts / IIASA on GAINS emission calculations (but not on energy scenarios!) to improve the EC4MACS Final Assessment
 - Submission of national energy/agricultural scenarios to IIASA for implementation in GAINS. GAINS data templates with PRIMES data will be provided by IIASA.

5

Revision of the NEC directive

- ◆ Work programme for the determination of emissions in 2020 – 2030
 - March-September:
 - New PRIMES 2012 baseline, with consultations of DG-ENER/PRIMES with MS energy experts
 - June:
 - Draft TSAP baseline (including first MS comments) presented to ESG
 - Further feedbacks to IIASA up to September
 - December 2012:
 - Final TSAP baseline(s)

6

Agenda

- ◆ Information Gothenburg Protocol revision, NEC directive revision, LCP BREF process
 - ◆ Outcomes of the kick off meeting – objectives
 - ◆ General hypothesis
 - ◆ Co-firing of biomass
 - ◆ Investments and operating costs for SO₂ reduction techniques
 - ◆ Investments and operating costs for NO_x reduction techniques
 - ◆ Investments and operating costs for PM reduction techniques
 - ◆ Collection of investments covering the techniques considered by the group and thermal capacities > 50 MWth
 - ◆ Other issues
-

7

Main conclusions from the kick off meeting

Consider:

- ◆ Combustion plants > 50 MWth : investment functions to be developed for different ranges of size
(50 – 100 MW; 100 – 300 MW (or 500) – > 300 MW (or 500))
- ◆ Hard coal (HC), brown coal (BC), HFO and natural gas + **biomass wood** in co-firing up to 20 % with coal (non commercial gases and blast furnaces not covered)
- ◆ Different load factors (included in the cost function)
- ◆ Boilers and gas turbines (not yet stationary engines)
- ◆ Retrofit factor for existing plants : different retrofit factor according to different techniques

Derive:

- ◆ Yearly costs provided but also cost effectiveness (€/t pollutant eliminated), cost per MWth and or MWe as well as costs per MWh for different load factors
-

8

Agenda

- ◆ Information Gothenburg Protocol revision, NEC directive revision, LCP BREF process
- ◆ Outcomes of the kick off meeting – objectives
- ◆ General hypothesis
- ◆ Co-firing of biomass
- ◆ Investments and operating costs for SO₂ reduction techniques
- ◆ Investments and operating costs for NO_x reduction techniques
- ◆ Investments and operating costs for PM reduction techniques
- ◆ Collection of investments covering the techniques considered by the group and thermal capacities > 50 MWth
- ◆ Other issues

Fuels considered

Fuels :

- ◆ BC: Brown coal – Low calorific value between 15 to 20 GJ/t; S ?
- ◆ HC1: Hard coal grade 1 – Low calorific value between 26 to 32 GJ/t, S > 1% w/w
- ◆ HC2: Hard coal grade 2 – Low calorific value between 26 to 32 GJ/t, S : 0.6 to 0.8 % w/w
- ◆ HC3: Hard coal grade 3 – Low calorific value between 26 to 32 GJ/t, S < 0.6 % w/w
- ◆ HF1: Heavy fuel oil grade 1 - Low calorific value between 38 to 42 GJ/t, S > 1 % w/w
- ◆ HF2: Heavy fuel oil grade 2 - Low calorific value between 38 to 42 GJ/t, S : 0.5% to 1 % w/w
- ◆ HF3: Heavy fuel oil grade 3 - Low calorific value between 38 to 42 GJ/t, S < 0.5% w/w
- ◆ Gas: HHV: 30-47 MJ/Nm³ (L-Gas / H-Gas), S : 0.00012 to 0.0013 % w/w
- ◆ OS1: Wood - Low calorific value between 13 to 18 GJ/t, S # 0% w/w

Dry waste gas flow rates per unit of energy considered

Boilers :

- ◆ For solid fuels (coals): $F_{ref} = 350 \text{ Nm}^3/\text{GJ}$ (6 % O₂, dry)
- ◆ For liquid fuels: $F_{ref} = 280 \text{ Nm}^3/\text{GJ}$ (3 % O₂, dry)
- ◆ For gaseous fuels: $F_{ref} = 270 \text{ Nm}^3/\text{GJ}$ (3 % O₂, dry)
- ◆ What factor for wood ?

To be checked by experts

Other data to be used ? data from the CEN standard in elaboration to be used?

Gas Turbines:

- ◆ Conversion of 270 Nm³/GJ (3% O₂) to 810 Nm³/GJ (15% O₂)

11


Real condition waste gas flow rates per unit of energy (useful to use some references)

- ◆ For solid fuels (coals): $F_{real} = ? \text{ Nm}^3/\text{GJ}$ (% O₂ real condition, humid)
- ◆ For liquid fuels: $F_{real} = ? \text{ Nm}^3/\text{GJ}$ ((% O₂ real condition, humid)
- ◆ For gaseous fuels: $F_{real} = ? \text{ Nm}^3/\text{GJ}$ ((% O₂ real condition, humid)
- ◆ For biomass wood: $F_{real} = ? \text{ Nm}^3/\text{GJ}$ (% O₂ real condition, humid)

Boiler	% O2 real	Temp K	H real %	P real Pa
HC				
BC				
HFO				
Natural gas				
Wood				

12

Chemical Engineering Plant Cost Index



13

Exchange Rates USD / EUR 1990-2011

Year	Annual Average DEM/USD	Min	Max	Year	Annual Average ECU/USD	Min	Max	Year	Annual Average EUR/USD	Min	Max
2001	0,458	0,429	0,488	2001	0,896	0,838	0,955	2011	1,392	1,289	1,488
2000	0,472	0,422	0,531	2000	0,924	0,825	1,039	2010	1,327	1,194	1,456
1999	0,545	0,512	0,603	1999	1,066	1,002	1,179	2009	1,394	1,256	1,512
1998	0,568	0,538	0,615	1998	1,121	1,070	1,212	2008	1,471	1,246	1,599
1997	0,579	0,532	0,651	1997	1,135	1,049	1,258	2007	1,371	1,289	1,487
1996	0,674	0,641	0,717	1996	1,270	1,238	1,318	2006	1,256	1,180	1,333
1995	0,707	0,642	0,742	1995	1,308	1,222	1,357	2005	1,245	1,167	1,362
1994	0,619	0,568	0,675	1994	1,189	1,104	1,284	2004	1,243	1,180	1,363
1993	0,606	0,576	0,637	1993	1,172	1,113	1,244	2003	1,131	1,038	1,263
1992	0,643	0,596	0,721	1992	1,297	1,207	1,458	2002	0,946	0,858	1,049
1991	0,604	0,545	0,685	1991	1,240	1,120	1,408				
1990	0,619	0,582	0,679	1990	1,273	1,185	1,395				

14

Exchange Rates GBP / EUR

1990-2011

Year	Annual Average DEM/GBP	Min	Max	Year	Annual Average ECU/GBP	Min	Max	Year	Annual Average EUR/GBP	Min	Max
2001	0,318	0,305	0,328	2001	0,622	0,597	0,641	2011	0,868	0,832	0,905
2000	0,312	0,292	0,327	2000	0,609	0,571	0,640	2010	0,858	0,810	0,911
1999	0,337	0,318	0,364	1999	0,659	0,622	0,712	2009	0,891	0,843	0,961
1998	0,343	0,321	0,363	1998	0,676	0,639	0,714	2008	0,797	0,733	0,979
1997	0,354	0,326	0,384	1997	0,693	0,646	0,742	2007	0,685	0,655	0,735
1996	0,432	0,382	0,462	1996	0,814	0,737	0,850	2006	0,682	0,668	0,701
1995	0,448	0,411	0,468	1995	0,829	0,784	0,857	2005	0,684	0,662	0,707
1994	0,404	0,382	0,422	1994	0,776	0,743	0,802	2004	0,679	0,656	0,709
1993	0,403	0,387	0,429	1993	0,780	0,751	0,829	2003	0,692	0,650	0,724
1992	0,366	0,340	0,423	1992	0,737	0,698	0,820	2002	0,629	0,609	0,651
1991	0,342	0,334	0,353	1991	0,701	0,689	0,716				
1990	0,347	0,329	0,368	1990	0,714	0,682	0,750				

15

Agenda

- ◆ Information Gothenburg Protocol revision, NEC directive revision, LCP BREF process
- ◆ Outcomes of the kick off meeting – objectives
- ◆ General hypothesis
- ◆ Co-firing of biomass
- ◆ Investments and operating costs for SO₂ reduction techniques
- ◆ Investments and operating costs for NO_x reduction techniques
- ◆ Investments and operating costs for PM reduction techniques
- ◆ Collection of investments covering the techniques considered by the group and thermal capacities > 50 MWth
- ◆ Other issues

16

How can we include Biomass (Wood) Co-Firing?

- Limit type of co-firing to hard coal PC units with discrete amount of co-firing shares (i. e. 5%, 10%, 20%).
- Effect Calculation:
 - a) Define 100% biomass-only numbers (derive from e.g. Swedish data) and calculate co-firing cases by taking the weighted average
 - or
 - b) Take values from existing Co-Firing cases (if accessible)

To be done for: emissions at equipment inlet / outlet,
equipment abatement efficiency, equipment lifetime (if applicable)

17

Effects of Biomass (Wood) Co-Firing – SO₂

S-content of wood: 0% => Reduction of SO₂ emissions by amount of co-firing percentage

18

Effects of Biomass (Wood) Co-Firing – PM

Different ash behaviour in boiler and in ESP, different fouling in ESP etc.

19

Effects of Biomass (Wood) Co-Firing - NO_x

- Reduction of pre-SCR NO_x emissions due to lower combustion temperature. This effect will decrease for newer LNBS.
- Higher catalyst deactivation rates => Shorter operating cycles between regeneration.
- Effect on possible no. of regenerations not known.
- Experiences: Mainly in DK and NL, in SE with biomass-only plants.

20

SO₂ reduction techniques considered

Wet Flue Gas Desulphurisation with limestone (LSFO : limestone forced oxidation, and LSNO : limestone natural oxidation)

Wet Flue Gas Desulphurisation with lime?

Dry flue gas desulphurisation for small installation with lime


21

Agenda

- ◆ Information Gothenburg Protocol revision, NEC directive revision, LCP BREF process
- ◆ Outcomes of the kick off meeting – objectives
- ◆ General hypothesis
- ◆ Co-firing of biomass
- ◆ Investments and operating costs for SO₂ reduction techniques
- ◆ Investments and operating costs for NO_x reduction techniques
- ◆ Investments and operating costs for PM reduction techniques
- ◆ Collection of investments covering the techniques considered by the group and thermal capacities > 50 MWth
- ◆ Other issues

22

Investments for DeSO_x - LSFO



23

Investments

Collect investments from real cases to cover the whole range of power – See the last slides and the list of parameters

24

Variable operating costs : limestone

Limestone demand current EGTEI data:

Efficiency of SO ₂ removal η	t CaCO ₃ /t SO ₂	Ratio Ca/S
85.0%	1.41	0.90
90.0%	1.48	0.95
95.0%	1.59	1.02

Purity of limestone less than 100 %, reactivity less than 100 %.

Efficiency of SO ₂ removal η	t CaCO ₃ /t SO ₂	Ratio Ca/S
85.0%	1.48	0.95
90.0%	1.56	1.00
95.0%	1.67	1.07

λ^s : specific limestone demand in ton CaCO₃/ton SO₂ removed to be checked by experts;
 Other data expected to derive the correct demand of CaCO₃ for different efficiencies of reduction

25

Variable operating costs : lime

Lime demand :

λ^s : specific lime demand in ton CaO/ton SO₂ removed to be provided ; Other data expected to derive the correct demand of CaO for different efficiencies of reduction

26

Variable operating costs : reagent prices

Limestone prices : between 30 to 40 € / t in France. Other data?

Lime prices : ?

27

Variable operating costs : water consumption

Limestone slurry:

Solid concentration from 15 – 20 % ? 30 % ?

Validate the concentration to be taken into account in case of LSFO and LSNO

Lime slurry:

Solid concentration ?

Validate the concentration to be taken into account in case of LSFO and LSNO

Water losses and purges to be compensated : 10 % of water demand

To be validated

28

Variable operating costs : byproducts

With LSNO

$I^{bp} = I^s \times 136/100$ in case of byproduct (CaSO_3) produced

With LSFO:

$I^{bp} = I^s \times 151/100$ in case of gypsum produced

Prices of waste disposal ? €/t

Prices of gypsum sold ? €/t ? Depend on the quality?

29

Variable operating costs : electricity consumption

Electricity demand to overcome the pressure drop and auxiliary equipment such as mist eliminator...

Data from the literature :

Coal with 1.3% S, efficiency 98% : 5.46 MW for equipment for an installation of 500 We or 1.1% of the net electricity production

LSFO : coal 1% S : 1.1 % of gross electrical output

coal 2.25 % S : 1.5 %

LSNO : coal 2.25 % S : 1.0 % of gross electrical output

LSFO 90 % efficiency : 10 to 12 MW for a unit of 600 MWe

Obtain data to derive a function according to the sulphur content of coal or liquid fuel and the efficiency of desulphurisation required (LSFO and LSNO). Differences between LSFO and LSNO to be taken into account.

30

Variable operating costs : wages

Wages

Data from the literature :

12 operators (40 hours/week) for an existing 500 MWe and 8 for a new,
10 operators for a 600 MWe

λ^{wage} : specific demand in human resource for control of the FGD and its operation as well as maintenance operation in number of operators.

Function according to the size to be determined from examples provided by experts for LSFO and LSNO.

Is the factor constant according to the size?

31

Fixed operating costs

Fixed operating costs depend on the capacity or size of the installation, i.e. on the investment and are expressed as a percentage of the unit investment.

They include costs of maintenance and repair, insurance, administrative overhead, etc. Taxes are not included in order to be coherent with GAINS.

According to one reference , fixed operating costs are 2.5 % of investment for an existing plant and 3.3 % for a new installation.

EGTEI considered 4 % of the investment.

Percentage to be validated: 4 % of the investment or another factor. Is the factor lower for LSFO than for LSNO?

32

Agenda

- ◆ Information Gothenburg Protocol revision, NEC directive revision, LCP BREF process
 - ◆ Outcomes of the kick off meeting – objectives
 - ◆ General hypothesis
 - ◆ Co firing of biomass
 - ◆ Investments and operating costs for SO₂ reduction techniques
 - ◆ Investments and operating costs for NO_x reduction techniques
 - ◆ Investments and operating costs for PM reduction techniques
 - ◆ Collection of investments covering the techniques considered by the group and thermal capacities > 50 MWth
 - ◆ Other issues
-

33

DeNO_x equipment

- Primary Measures:
 - Low NO_x Burner (LNB) for all types of LCP
 - FGR possibly for gas furnaces
 - Water / Steam Injection for Gas Turbines
 - Secondary Measures:
 - SCR for all types of LCP
 - SNCR (for certain cases only – which?)
-

34

Typical / Reported NO_x Emissions [Heinze 1999, Rentz 2002]

NO _x Emissions (mg/Nm ³)	HC-PC	BC-PC	CFB-HC	CFB-BC
Baseload (w/o LNB)	800-1,300 ⁽¹⁾	500-800	< 200	< 200
LNB (pre-1999)	300-500	140-175	-	-
LNB+SCR	90-200	-	-	-

NO _x Emissions (mg/Nm ³)	Oil-HSFO	CCGT-HEL	CCGT-Gas
„Primary Measures“	-	-	40-120
Water Injection	-	260	-
LNB+SCR	120-130	-	-

(1): Lower End of Range for Tangentially Fired Boiler, Upper End of Range for Wall Fired Boiler

35

Suggested Default Emission Levels

NO _x Boiler Outlet Emissions in mg/Nm ³ at corrected O ₂ -Level	Baseload	1°/LNB 1st Generation	1°/LNB 2nd Generation	1°/LNB 3rd Generation
Lignite	650	300	200	150
Hard Coal (Bit) – Tang.	800	500	400	300
<i>Hard Coal (Bit) – Wall.</i>	<i>1,100</i>	<i>700</i>	<i>550</i>	<i>400</i>
Heavy Fuel Oil	1,000			
GAS – GT		50	25	
GAS – Furnace				

36

Current SCR Benchmark for Coal Fired Power Plants [Heiting 2011]

- NO_x conversion: 90%
- Minimum NO_x outlet concentration at plants with new generation LNBS: 35-40 mg/Nm³
- NH₃ slip < 1 ppmv
- Catalyst regeneration each 1-3 years (low end for biomass co-firing)
- SCR setup in general 3 catalyst layers, sometimes up to 5 layer

37

NO_x Emissions at SCR Outlet:

- NO_x emissions at existing HC-fired PC-plants:
1st and 2nd generation LNB + (3+1) SCR:
130-180 mg/Nm³
- ELVs of Dutch installations of 2005 and later¹:
CCGT: 20 mg/Nm³ (15% O₂)
Gas Furnace: 25 mg/Nm³ (3% O₂)
Coal/Biomass: 50-65 mg/Nm³ (6% O₂)

38

(1) Data on NL permits provided by Infomil

Next Steps for NO_x (I)

- Validation / Comments on presented data to fill out the following table:

	HC-PC	HC-CFB	BC-PC	BC-CFB	Oil - B	GAS - B	GAS - CCGT
Baseline							
1st Gen. PM							
2nd Gen. PM							
3rd Gen. PM							
SCR	Only, if calculating with an average / individual abatement efficiency is not suitable						
(SNCR)							

39

Next Steps for NO_x (II)

Suggestion for SCR default values (derived from HC cases):

- average abatement efficiency (3+1 layer): 85%
- average NH₃ consumption: 0.3 t NH₃/t NO_x abated (SR: 0.85)
- Power consumption: 0.3% of gross electrical output
- Total catalyst lifetime: 75,000 hrs
- Catalyst regeneration: every 15,000 hrs (fossil fuel-only)
- Specific amount of catalyst needed: 0.32 m³/MW_{th}

40

Next Steps for NO_x (III)

- Agree on SCR catalyst data (lifetime, spec. catalyst volume, regeneration cycles, etc.)
- Decide, whether to include SNCR/FGR or not
- Decide, how to proceed with different size classes (do technical numbers change?)
- Decide on how to modify catalyst lifetime when co-firing biomass (which numbers, e. g. 1/3 of fossil-fuel only?)

41

Agenda

- ◆ Information Gothenburg Protocol revision, NEC directive revision, LCP BREF process
- ◆ Outcomes of the kick off meeting – objectives
- ◆ General hypothesis
- ◆ Co-firing of biomass
- ◆ Investments and operating costs for SO₂ reduction techniques
- ◆ Investments and operating costs for NO_x reduction techniques
- ◆ Investments and operating costs for PM reduction techniques
- ◆ Collection of investments covering the techniques considered by the group and thermal capacities > 50 MWth
- ◆ Other issues

42

PM reduction techniques

	10 mg/Nm ³	20 mg/Nm ³	30 mg/Nm ³	50 mg/Nm ³
FF	y	y	y	y
2 fields ESP	n	n	With FGD?	With FGD?
3 fields ESP	n	With FGD?	y	y
4 fields ESP	?	y	y	y
6 fields ESP	y	y	y	y

From Simon Schulte – determination of costs for activities of annexes IV, V and VII for boilers and process heaters

 43

PM reduction techniques

- Provide information on wage demand for FF and ESP
- Provide information on electricity consumption :
 - Pressure drop for ESP and FF
 - Power needed for electrodes and pulse jet cleaning

	FF		ESP	
	Pressure drop mbar	Power for pulse jet cleaning	Pressure drop mbar	Power for electrodes
5 mg/Nm ³	10 to 12	1360 kW for a 800 MWe burning coal	3 to 4	1060 kW for a 800 MWe burning coal
10 mg/Nm ³	?	?	?	?
20 mg/Nm ³	?	?	?	?

 44

PM reduction techniques

- Bag lifetime : 20000 to 30000 hours ?
- What is done with dust recovered (waste disposal, recovery) ?
- Prices of waste disposal or dust sold?

45

Agenda

- ◆ Information Gothenburg Protocol revision, NEC directive revision, LCP BREF process
- ◆ Conclusions from the kick off meeting – objectives
- ◆ General hypothesis
- ◆ Co firing of biomass
- ◆ Investments and operating costs for SO₂ reduction techniques
- ◆ Investments and operating costs for NO_x reduction techniques
- ◆ Investments and operating costs for PM reduction techniques
- ◆ Collection of investments covering the techniques considered by the group and thermal capacities > 50 MWth
- ◆ Other issues

46

Collection of investments

Questionnaire

List of parameters to be collected to characterise the installation for which investments will be provided:

- ◆ Age of the installation, thermal capacity MWth,
- ◆ Short description of the installation (number of boilers linked to the FGD, type of boiler) – new or existing installation when the reduction technique was installed?
- ◆ Fuels used : type, low calorific value, % S, ash content (HC1 to 3; BC; HF, NG, wood),

47

Collection of investments

List of parameters to be collected to characterise the installation for which investments will be provided:

For each process considered : LSFO, LSNO, SCR, SNCR, ESP, FF, LNB, other techniques if necessary

- ❖ information on the reduction technique,
- ❖ Inlet concentration of SO₂, NO_x or PM to be abated (according to the technique),
- ❖ Outlet average SO₂, NO_x or PM concentrations obtained (according to the technique) - Efficiency
- ❖ Year of the investment, investment for each technique
- ❖ Components of the costs included in the investments provided (detail the components taken into account for comparison reason)

48

Agenda

- ◆ Information Gothenburg Protocol revision, NEC directive revision, LCP BREF process
- ◆ Conclusions from the kick off meeting – objectives
- ◆ General hypothesis
- ◆ Co-firing of biomass
- ◆ Investments and operating costs for SO₂ reduction techniques
- ◆ Investments and operating costs for NO_x reduction techniques
- ◆ Investments and operating costs for PM reduction techniques
- ◆ Collection of investments covering the techniques considered by the group and thermal capacities > 50 MWth
- ◆ Other issues