

EGTEI – Expert Group on Techno Economic Issues

Results of EGTEI study on APATITY Power Plant

Nadine Allemand
Надин Альманд

EGTEI Technical Secretariat
(CITEPA)

30 November 2012

MURMANSK MEETING 2012

EGTEI

Murmansk meeting

Content of the presentation

- ✓ Characteristics of the power plant
- ✓ Available techniques to reduce emissions of SO₂, NO_x and TSP
- ✓ Costs assesement

EGTEI

Apatity power plant

Apatity power plant: 10 boilers and 8 steam turbines for heat and electricity generation – 1700 hours/year full load

Boiler capacities : rated thermal input of 153 MWth

Total rated thermal input of the plant: **1 530 MWth**

Bituminous and sub bituminous coals used:

Type of fuels consumed	Low calorific value	Ash content in operating conditions	Fuel consumption 2010
	GJ/t	% w/w	kt
Intinskiy (Sub bituminous)	22.8	27.4	62.3
Vorkutinskiy (Sub bituminous)	22.6	21.4	167.4
Kuznetskiy (Bituminous)	17.8	16.8	171.3
Fuel oil	39.9		0.65

Sulphur content from 1.2 to 1.5 % w/w

EGTEI

Apatity power plant

Apatity power plant: equipped with venturi scrubbers to limit TSP emissions

Total emissions	2008	2010
	kt	kt
Dust before venturi scrubber (anabated emissions)	91.3	84.6
Dust after venturi scrubber (abated emissions)	6.5	6.0
NOx	2.4	2.3
SO ₂ (based on a sulphur content in coals of 1.5 %)	13.1	12.1

EGTEI

Gothenburg Protocol Option considered for cost estimation of reduction techniques

	Anabated average concentrations observed			
		mg/m³ STP (Standard Temperature and Pressure) and 6 % O₂		
Dust	30 500			
NO _x	815			
SO ₂	4 370			

30 November 2012

5

EGTEI

Gothenburg Protocol ELVs considered for cost estimation of reduction techniques

	Average concentrations observed	Options for ELVs as suggested by EGTEI for Boilers > 500 MWth in technical Annexes IV, V and VII		
		Option 1	Option 2	Option 3
		mg/m³ STP and 6 % O₂		
Dust	30 500	10	20	50
NO _x	815	100	200	200
SO ₂	4 370	100	200	1 200

Abatement efficiency required for the Apatity plant:
 TSP : 99.9 % ; NO_x : 75.5 % and SO₂ : 95.4 %

30 November 2012

6

Available techniques

DeNOx:

Primary measures: not adapted for the reduction efficiency required

Selective Non Catalytic Reduction: not adapted for the reduction efficiency required

Selective Catalytic Reduction (SCR): adapted to the situation if installed in high dust configuration for temperature requirement

DeSOx (FGD: Flue Gas Desulphurisation):

Coals with very low sulphur content (less than 0.1 %) do not exist

LSFO: limestone with forced oxidation for gypsum production: largely used in the world.

LSNO: limestone with natural oxidation: not well suited

Available techniques

Dedusting:

Both Electrostatic Precipitators (ESP) and Fabric Filters (FF) could be use.

Venturi scrubbers in place not sufficiently efficient

Selected techniques

Apatity plant:


A chain **SCR** (Selective Catalytic Reduction) to remove NO_x, **ESP** (Electrostatic Precipitator) to remove dust and **wet FGD** (Flue Gas desulphurisation) by LSFO taken into account

Due to too low outlet temperatures, venturi scrubbers (less than 70 °C) not kept in operation to avoid reheating of flue gases for the SCR


Cost assessment carried out for the following chain:

- ✓ Each boiler equipped with its own small SCR unit, followed by an ESP
- ✓ After the ESPs, waste gases collected and conveyed towards a unique FGD unit. FGD with forced oxidation. Gypsum recovered


Selective catalytic reduction (SCR)



Electrostatic precipitator – ESP



Flue gas desulphurisation with limestone forced oxidation



Cost estimation

✓ **Investments (INV : k€ or M€):**

Amount paid for the reduction technique ready to be used – Retrofit factor for existing installations

✓ **Annualised capital costs (ACC : k€/y):**

Investments annualised taking into account the interest rate and the life time of the equipment

✓ **Fixed operating costs (OC_{fix} : k€/y):**

Costs of maintenance and repair, administrative overhead, etc.

✓ **Variable operating costs (OC_{var} : k€/y):**

Depending on the technique: costs of electricity, reagents (CaCO₃, NH₃), water, waste disposal...

✓ **Total annual costs: (C_{tot} : k€/y):**

$$C_{\text{tot}} = \text{ACC} + \text{OC}_{\text{fix}} + \text{OC}_{\text{var}}$$

Estimation of costs

✓ **Investments (INV : k€ or M€):**

Available EGTEI investment functions updated taking into account recent data on costs of the literature. Costs expressed in € of 2010

✓ **Annualised capital costs (ACC : k€/y):**

Investments annualised taking into account the interest rate of 4 % as in EGTEI

Life time of the equipment of 15 years

✓ **Fixed operating costs (OC_{fix} : k€/y):**

Costs estimated to 4 % of the investments

Estimation of costs

✓ Variable operating costs (OC_{var} : k€/y):

- labour demand,
- electricity consumption,
- water consumption,
- chemical consumption (reagent such as $CaCO_3$, NH_3 ...)
- byproduct cost (landfilled) / profit (when sold as gypsum...),
- ...

Use of the cost functions developed by EGTEI with update for some criteria

Estimation of costs

✓ Prices used for definition of variable operating costs (country specific):

The prices of utilities, wages, and reagents taken into account are as follows :

Electricity: 0.1 €/kWh

Wages: 6 k€/person/year

Waste disposal: 8.3 €/t

Limestone: 20 €/t $CaCO_3$.

NH_3 : 400 €/t NH_3 . Cost assumed to be similar to costs in the EU

SCR catalyst : 20 000 €/m³

Estimation of costs

	SO₂	NO_x	TSP
Investments - M€ ₂₀₁₀	63.6	62.9	30.7
Operating costs - M€ ₂₀₁₀ / year	5.0	2.9	2.1
Total annual costs - M€ ₂₀₁₀ /year	10.7	9.7	4.9
Initial annual average emissions tons/year	12 612	2 352	87 961
Emissions abated tons/year	12 034	1 764	87 903
Pollutants emitted after treatment tons/year	578	588	58
Cost € ₂₀₁₀ /t pollutant abated	892	5 509	56

Conclusions

- ✓ The EGTEI methodology for estimating costs in LCP successfully applied to estimate costs in a LCP in Russia
- ✓ Experience could be replicated with other sectors/plants
- ✓ Provide useful information for estimating the economical impact of a regulation
- ✓ Site specific engineering cost study would be necessary to define more accurately the costs. As example, complexity of the retrofit not known for the Apatity plant. Costs probably underestimated (place available, destruction of old equipment, control command...)



Centre Interprofessionnel Technique d'Etudes de la Pollution Atmosphérique



Thank you for your attention
Спасибо

Nadine ALLEMAND
Deputy director
Nadine.allemand@citepa.org

30 November 2012



Centre Interprofessionnel Technique d'Etudes de la Pollution Atmosphérique

CITEPA – 7, Cité Paradis – 75010 PARIS - +33 (0)1 44 83 68 83 – www.citepa.org