



**NO_x abatement in Swedish large and medium sized combustion plants
- fuelled with biomass,
- or used for co-incineration for energy production**

Staffan Asplind, Swedish EPA
22nd EGTEI Meeting - Nice, 18 October 2013

2013-10-28

1



mg/MJ!

Multiply mg/MJ with

2,5 (for biomass with 50 % moisture), or
2,8 (for biomass with 20 % moisture)

to get mg/Nm³ at 6 % O₂

Multiply mg/MJ with

1,8 (for biomass with 30 % moisture)

to get mg/Nm³ at 11 % O₂





Summary

- In combustion & co-incineration plants (in the Swedish Energy and Industrial Sectors) biomass and biomass waste predominate
- Primary measures to abate NOx are frequent and sophisticated
- For biomass combustion & co-incineration for energy production:
 - ~ 150 units have SNCR
 - Typically 50 - 120 mg/MJ with SNCR
 - ~ 20 units have, or have had SCR
 - Almost all installed SCR are either removed or are now used as slip-SCR
 - 7 - 10 have Slip SCR (as high dust) in combination with SNCR



Combustion Plants in Sweden

- *Units = mostly boilers (and some gas turbines)*
- *Plants = all the units at the site*
- ~ 700 combustion plants EU ETS
 - ~ 430 units Swedish "NOx Charge"
- ~ 140 LCP plants (with ? 300 units)
 - ~ 80 WID plants (with 135 units)
- **Major product = Heat for district heating: 50 - 60 TWh annually**
 - + Power at CHPs & Industry: ~ 14 TWh
 - + Steam at Industry: 10 TWh
 - + District cooling: ~ 1 TWh
 - + Condensed Power: ~ 0,3 TWh





Energy Statistics Sweden

Energy Sector:

- 400+ district heating nets
- ~ 70 CHP plants with 10 TWh power production
- 70 TWh thermal input for heat and CHP:
 - ~ 40 % biomass + ~ 25 % waste
 - ~ 9 % fossil + ~ 4 % peat
 - ~6 % flue gas condensation

Industry Sector:


- 15 TWh biomass for steam and power production in:
 - Pulp & Paper (10 TWh excluding recovery boilers)
 - Saw Mills (4 TWh)



Typical plant in the Energy Sector in Sweden - Today

Example:

- Boiler 4 - CHP - 2007 - base load - "co-incineration plant"
 - » waste wood and other waste fuels
 - » some virgin wood
- Boiler 3 - CHP - 1984 - mid meritt - built for coal, but retrofitted to wood chips
- Boiler 2 - Heating Water - 1971 - peak load - bio oil
- Boiler 1 - Heating Water - 1966 - reserve load - gas oil





Primary measures at biomass boilers in Sweden

Primary measures important Role

Together with hour to hour focus

- Staged combustion, of course
 - Including
 - Rotating Over Fire Air
 - Ecotube
 -
- Recirculation of Flue Gas
- Injection of water or steam in boiler
- Cooling of combustion air
- Sulphur injection
- ... and others



SNCR vs SCR for new biomass and co-incineration boilers

- Above 40 mg/MJ SNCR is first choice
 - since economy is determining factor
- Below 40 mg/MJ SCR is probably the best option,
 - or for lower levels: the only choice

Estimated Costs for 75 MW_{th} Biomass Boiler

	<i>Investment</i>	<i>Ammonia</i>	<i>Catalyst</i>
• SCR	5 million €		Deactivation Rate critical
• SNCR	1 million €	2-3 times more than SCR	---

Estimated annual Costs in € per kg NOx

	<i>Cost</i>	<i>Being installed at (*)</i>
• Primary measures	1 - 2	all units more or less
• SNCR	1,5 - 3	~ 150 units
• SCR	4 - 20	1 unit 10 units (slip-SCR)

Calculation method:

- Depreciation during:
 - 10 years for primary measures and SNCR
 - and 20 years for SCR
- Interest rate 10 % (!!)

(*) = biomass and co-incineration



SNCR

- at biomass and co-incineration boilers


- Yearly averages range from 13 to 150 mg/MJ thermal input
 - 70 % of units: 50 - 120 mg/MJ yearly average
 - Upper end of interval quite high
 - Existing boilers have been retrofitted

~ 150 units (i.e. boilers) in Sweden today have SNCR

~120 with ammonia

~ 25 with urea


~ 8 with ammonium sulphate



SNCR

Conditions that must be fulfilled :

- Temperature levels
- Reaction times
- Injection at several levels
- NH_3 slip



High Dust SCR
- at biomass and co-incineration boilers

- Beginning of the 90:s: Some coal boilers converted to biomass
Catalysts removed or now used as slip-SCR
- Biomass & Tyres/ Recycled wood/ Paper&Plastics
Deactivation ~ 50 % per year
1993-2000 Norrköping, 1994 - 2004 Nyköping
- Coal co-combusted with 10-15% Biomass
Deactivation 10-20 % per year
DK, NL, ...

Boiler, Reactor with Catalyst, Filter, Gas Scrubber, Stack

SNCR and Slip SCR in High dust position
- at biomass and co-incineration boilers


- Installed at ~ 6 biomass plants since 1997
- 15 - 55 mg/MJ
- ~ 8 - 20 % deactivation per year
- Catalyst elements exchanged after 3 - 7 years

Boiler, Reactor with Catalyst, Filter, Gas Scrubber, Stack

**Low Dust SCR - after dust abatement
- at biomass and co-incineration boilers**


Only few installations:

- % Bio and % Peat
since 2010 - Umeå
15 mg/MJ yearly average
- 50 % Bio and 50 % Peat
Deactivation <10 % per year
1994-2000 Kiruna



**Tail End
- at biomass and co-incineration boilers**

- Waste incineration plants: Dominating
-Deactivation ~ 1-3 % per year
- (As far as we know) Not used in Sweden for pure biomass
- Heat exchanger cost ~ 1 million €
- Need of net extra energy
+ 1-2 MW
for a 75 MWth boiler





Summary - *Once again!* 😊

- In combustion & co-incineration plants (in the Swedish Energy and Industrial Sectors) biomass and biomass waste predominate
- Primary measures to abate NOx are frequent and sophisticated
- For biomass combustion & co-incineration for energy production:
 - ~ 150 units have SNCR
 - Typically 50 - 120 mg/MJ with SNCR
 - ~ 20 units have, or have had SCR
 - Almost all installed SCR are either removed or are now used as slip-SCR
 - 7 - 10 have Slip SCR (as high dust) in combination with SNCR



Thank you for your attention


And a special thank to:

- The colleagues at the Administration of the NOx Charge
- The Swedish Thermal Engineering Research Institute ("Värmeforsk")

staffan.asplind@swedishepa.se

Swedish EPA
Stockholm

+ 46 (0)10 698 13 33



NATURVÅRDSVERKET

The Swedish Charge on NO_x

Some extra slides

NATURVÅRDSVERKET

The Swedish Charge on NO_x

Applies to boilers & gas turbines for energy production with Energy production > 25 GWh per year



FIXED
5,5 € / kg NO_x

SUM usually:
~ 75 million €
per year

After each year Calculation
TOTAL SUM MONEY
divided with
TOTAL SUM PRODUCED ENERGY
→ ~ 1 € / MWh

~ SAME SUM:
~ 75 million €
per year

The Swedish EPA
Administration
½ million €





Why the NOx Charge have been successful

- High charge level (5,5 € per kg)
- Every kilogram counts
 - Focus at NOx levels from hour to hour by personnel for operation of the plant
- Measures for decreasing emissions are taken at plants where the cost is least
- Reduced effect on competition due to the refund construction
- Technology development
- Winners and losers in every sector → Rather well received
- Very low administration cost (<1%)



Net yearly economic result for all ~ 400 boilers - individually under the NOx charge

