

# Some deNOx process for large combustion systems



3rd TFTEI Annual Meeting  
UN-ECE CONVENTION ON LONG-RANGE  
TRANSBOUNDARY AIR POLLUTION  
- Rome, October, 20, 2017

Christophe CORD'HOMME  
CNIM Group  
Business & Products Development Director



# ENIM

An international family-owned  
industrial group  
created in 1856

Workshop in 1895



**ENIM**



**The turn key project culture of  
a former Naval Shipyard!**

A photograph of the WtE Sheffield, UK, taken at night. The image shows a large industrial building with a prominent tall, white chimney on the left. The building is illuminated with warm lights, and a curved section of the roof is lit with a rainbow-colored light strip. The sky is a deep blue, and the foreground is dark with some grass and trees.

# **ENIM** TURNKEY PROJECT designer and supplier for Environment and Energy...

**WtE Sheffield, UK**

# ...Designing and building High Tech industrial EQUIPMENT and SYSTEMS...




Energy for the Future !  
Radial plates for ITER FUSION reactor!

**ENIM**



Completed by **SERVICES** like engineering, project management, commissioning, Operation & Maintenance, retrofitting...



**ENIM**

# **ENIM** : Innovate and Act for Energy Transition and Circular Economy! (80% of Group orders in 2016)



**Thiverval sorting & WtE, Fr**

# ENIM



# BABCOCK

## Energy Transition : Energy management and efficiency of power plants and industrial sites

# **ENIM** recovers Energy from Municipal Solid Waste of 100 million people around the world!

Torino WtE, Italy by



**ENIM**

## Best Available Techniques for:

---

- Waste combustion
- Energy recovery
- Flue gas cleaning
- Power production

# Lab CNIM Group 443 Flue Gas Treatment lines in 26 countries since 1952!



Credit : BIG

WtE Amagerforbraending, Copenhagen, Denmark

**ENIM**




## Integrated and patented solutions to reduce all kind of emissions

- Turn-key flue gas treatment for
  - Waste-to-Energy Plants,
  - Biomass-to-Power Plants,
  - Fossil fuel fired Power plant (FGD)
- Scrubbers for marine industry
- Metal recovery from combustion residues



# Typical Pollutants to treat after combustion such as Municipal Solid Waste (MSW)


## Typical MSW Composition in Europe



## Pollutants from MSW Combustion



- CO<sub>2</sub>
- H<sub>2</sub>O
- N<sub>2</sub>
- CO
- **NO<sub>x</sub> (NO, NO<sub>2</sub>)**



- HCl
- HF
- **SO<sub>x</sub> (SO<sub>3</sub>, SO<sub>2</sub>)**



- Gas (Hg, Cd)
- Particles (Pb, Cu, Cr, Co...)



- Dioxins (PCDD/F) ...

Fly Ash and Bottom Ash

# Daily Emission Limit Values (ELVs) to air according to IED 2010/75/EU

## Industrial Emission Directive of 24/11/2010 for different industrial activities using solid fuels

SUBSTANCES/ACTIVITIES	ELVs in mg/Nm <sup>3</sup> (dioxins & furans in ng/Nm <sup>3</sup> )		Thermal Input (MW <sub>th</sub> )	Dust	TOC	CO	HCl	HF	SO <sub>2</sub>	NOx	Dioxins and furans	Cd + Tl	Hg	Heavy Metals (Sb + As + Pb + Cr + Co + Cu + Mn + Ni + V)	
Waste incineration & Co-incineration	at 11% O <sub>2</sub> dry	New & Existing > 3 t/h	~ 7	10	10	50	10	1	50	200 (expressed in NO <sub>2</sub> )	0.1	0.05	0.05	0.5	
Combustion Plants (coal, lignite and other solid residues)	at 6% O <sub>2</sub> dry (converted to 11% O <sub>2</sub> dry)	New & Existing	< 50	-	-	-	-	-	-	30 (20)	-	-	-	-	
		Existing (started operation until 7/01/2014)	50-100	30 (20)	-	-	-	-	400 (267)	300 (200)	-	-	-	-	-
			100-300	20 (13)	-	-	-	-	250 (167)	200 (133)	-	-	-	-	-
			> 300	20 (13)	-	-	-	-	200 (133)	200 (133)	-	-	-	-	-
			50-100	20 (13)	-	-	-	-	400 (267)	400 (267)	-	-	-	-	-
			100-300	20 (13)	-	-	-	-	200 (133)	200 (133)	-	-	-	-	-
Combustion plants (biomass)	at 6% O <sub>2</sub> dry	Existing (started operation until 7/01/2014)	50-100	30 (20)	-	-	-	-	200 (133)	300 (200)	-	-	-	-	
100-300			20 (13)	-	-	-	-	200 (133)	250 (167)	-	-	-	-	-	
> 300			20 (13)	-	-	-	-	200 (133)	200 (133)	-	-	-	-	-	
New			50-100	20 (13)	-	-	-	-	200 (133)	250 (167)	-	-	-	-	-
			> 300	20 (13)	-	-	-	-	150 (100)	150 (100)	-	-	-	-	-



**‘Efw’: Strictest European Environmental Legislation**

- ❑ **Incineration:** 20 components and lower ELVs (most stringent EU environmental Legislation)
- ❑ **Combustion Plants > 50 MWth:** Higher ELVs and for 3 pollutants only
- ❑ **Combustion Plants < 50 MWth:** no emissions limits

# Typical Abatement Performance of Pollutants in EfW



Typical Measured Values at Stack over ELVs EU Directive 2010/75/EC

Typical Measured Values at Stack over FGT Inlet




Measured values << ELVs (Emission Limit Values)


## Dry / Semi-dry (Vapolab)



## Semi-wet




## Wet



## Reactive agents


- Lime
- Sodium Bicarbonate
- Calcium carbonate
- Soda
- Activated carbon, lignite coke

# Abatement Technologies for deNOx (Secondary measures)




**SNCR (non catalytic)**

950 – 1050 °C



**SNCR + SCR  
Terminox<sup>®</sup>**

200 – 280 °C




**SCR (catalytic)  
CataLAB<sup>®</sup>**


180 – 250 °C

# SNCR deNOx (Selective Non Catalytic Reduction)

Reagent injection in the combustion chamber at high temperature (850 – 950°C)




# SNCR NO<sub>x</sub> conversion vs temperature & stoichiometry



# SNCR efficiency and ammonia slip



Influence on Temperature Window



- ▨ Range for NO<sub>x</sub>/NH<sub>3</sub>-optimised operation      "A" Optimum temperature for SNCR alone (low ammonia slip)
- ▨ Range for SNCR+SCR operation                      "B" Optimum temperature for SNCR + SCR (high ammonia slip)

Source EPPSA

# Abatement Technologies SCR de-NOx (Selective Catalytic Reduction)







# Different types of SCR deNOx (and dediox)

## Low dust SCR

## Tail end SCR

## Cold SCR

## Cold SCR with regeneration



260-280 °C  
High SO<sub>2</sub>  
e.g. Ivry (F)

220 – 250 °C  
Low SO<sub>2</sub>  
e.g. Twence (NL)

180 – 200 °C  
Very low SO<sub>2</sub>  
e.g. Aarhus(DK)

180 – 200°C  
low SO<sub>2</sub>  
e.g. Torino (It)



# BREF BAT main processes for NOx treatment


Process	SNCR	Combined SNCR +SCR	SCR – Low Dust	SCR –tail end	SCR –cold
• NOx reduction	+	++	++	++	++
• NH3 slip	0	+	+	+	+
• Dioxins reduction	No	No	Dioxin CAT	Dioxin CAT	Dioxin CAT
• Water/ Air compressed	+	+	+	+	+
• Dust	N.A.	ESP upstream	ESP upstream	BHF upstream	BHF upstream
• Reactive agents Consumption	+	++	++	++	++

**Overall INTEGRATED optimisation**  
**checking inter-process compatibility and interaction**  
**considering the technical and economical local situation.**

# BREF BAT main processes for NOx treatment


Process	SNCR	Combined SNCR+SCR	SCR –Low Dust	SCR –tail end	SCR –cold
<b>Costs</b>					
• OPEX	+	++	++	++	+
• CAPEX	+++	+	+	0	+
Footprint	++	+	+	0	0
Catalyst life time	NA	+	+	++	+
Maintenance	++	+	+	0	0
Other equipment	-	Upstr. ESP Downstr. Eco	Upstr. ESP Downstr. Eco	Gas/gas HEX or steam	Catalyst regeneration

- Average ambient air quality objective of  $40\mu\text{g}/\text{m}^3$  of  $\text{NO}_x$  in Paris Region for 2010 (11 millions of inhabitants on  $12.000\text{km}^2$ ).
- Main source of  $\text{NO}_x$  pollution (>50%) : dense traffic.



**Requires a reduction of 40% of the total emissions of  $\text{NO}_x$  compared to the situation in 2000**

- 19 EfW plants in Ile-de-France (IdF) - 4 millions of tons of MSW treated (1/3 of the national capacity) - Around 4% of the NO<sub>x</sub> emission in IdF in 2000.



**10 EfW plants in the near suburb of Paris (70% of the IdF capacity) with NO<sub>x</sub> ELV down to 80 mg/Nm<sup>3</sup> instead of 200 mg/Nm<sup>3</sup> required by the directive.**

**Reduction of the NO<sub>x</sub> contribution of EfW in Ile-de-France from 4% in 2000 to around 1%, instead of 2% obtained with the directive limit of 200mg/Nm<sup>3</sup>**



## Retrofit of the wet flue gas treatment of SYCTOM of PARIS – Saint-Ouen plant (France) 630.000t<sub>MSW</sub>/y


- 3 combustion lines capacity 28t MSW/h started in 1990 with grate furnace and steam boiler for cogeneration
- Existing wet flue gas treatment with liquid effluent discharge including electrostatic precipitator, quench and 1 wet scrubber started in 1990. Was in conformity with European directive 1989

**Main pollutants to treat :**  
**Dust and SOx (a few), dioxins and NOx 80mg/Nm<sup>3</sup> (PPA)**



Catalytic Treatment		Non Catalytic Treatment			
Selective Catalytic Reduction		On Wet Process		On Dry Process	
<i>Tail-end SCR</i>	Low dust SCR	<i>LAB scrubber without active carbon slurry</i>	<i>Downstream Bag-House</i>	<i>deNOx SCR</i>	<i>Upstream Bag-House</i>
<b>Solution</b>	<b>A</b>	<b>B</b>	<b>C</b>		
Performances Dioxins	<b>++</b>	+	<b>0</b>		
Performances Mercury	<b>0</b>	0	<b>+</b>		
Performances Dust and SOx	<b>0</b>	0	<b>+</b>		
Performances NOx	<b>++</b>	++	<b>0</b>		
Energy Consumption	<b>++</b>	+	<b>0</b>		





**Choice reasons of the tail-end SCR deNOx:  
NOx level,  
space available  
& flue gas temperature**




## Retrofit of the wet flue gas treatment of SYCTOM of PARIS XIII – IVRY plant (France) 730.000t<sub>MSW</sub>/y

- 2 combustion lines, started in 1969 : 50t MSW/h /line (WORLD RECORD SINCE ALMOST 48 YEARS), with grate furnace and steam boiler for cogeneration
- Existing wet flue gas treatment started in 1995 with liquid effluent discharge including electrostatic precipitator, quench and wet scrubber. Was in conformity with European directive 1989

Main pollutants to treat :  
**Dust (with an additional ESP),  
 dioxins and NOx 80mg/Nm<sup>3</sup> (PPA)**




Catalytic Treatment		Non Catalytic Treatment		
		On Wet Process		On Dry Process
Tail-end SCR	Low dust SCR	<i>dedioxLAB scrubber with active carbon slurry</i>	Downstream	Upstream
			A	B
Solution	A	B	C	
Performances Dioxins	++	+	++	
Performances Mercury	0	0	+	
Performances Dust and SOx	0	0	+	
Performances NOx	++	++	0	
Memory Effect Treat.t*	++	+*	++	
Energy Consumption	++	+	0	






## Flue gas treatment of SMITOM VAUX LE PENIL- MELUN new plant (FRANCE) 130.000t<sub>MSW</sub>/y

- 2 new combustion lines : capacity 8t MSW/h each started in 2003 with grate furnace and energy recovery boilers, producing each HP steam for electricity production (10MWe exported).
- 2 flue gas treatment lines based on semi-wet process, including an injection of atomised lime milk and active carbon in a reactor and a dedusting with a bag house filter. NOx treated with SNCR deNOx, consisting in an injection of ammonia-water in the furnace.
- In conformity with European directive 2010 but not concerned by the PPA requirement



	Catalytic Treatment		Non Catalytic Treatment	
	Selective Catalytic Reduction		On Wet Process	On Dry Process
	Tail-end SCR	Low dust SCR	dedioxLAB scrubber with active carbon	Downstream Bag-House filter + active carbon
			<b>deNOx SNCR</b>	<b>Upstream Bag-House filter + active carbon</b>
<b>Solution</b>			<b>E</b>	<b>F</b>
Performances Dioxins			0	++
Performances Mercurey			0	++
Performances Dust and SOx			0	++
Performances NOx			+	0
Energy Consumption			0	+



**Choice reasons:**  
**NOx level, integrated process giving optimum ratio for investment/operation costs**



# Some recent Dry/Semi-dry + SNCR FGT

- Gloucester - Urbaser (2019)
- South London - Viridor (2018)
- Leeds - Veolia (2016)
- Wilton - Suez (2016)
- Shropshire - Veolia (2015)
- Cardiff - Viridor (2015)
- Suffolk - Suez (2014)
- Plymouth - MVV (2014)
- Oxford - Viridor (2014)
- Stafford - Veolia (2014)
- Lincoln - WRG FCC (2013)
- Jersey - Government (2011)



# Some recent deSOx Marine scrubbers

*Mont St Michel – Marine Scrubbers – STX France*



*Pont Aven – STX France*



*Armorique – STX France*

# Some recent FGD for Power Plants

- SECOLAB with conditioning tower
  - SOLVAY Dombasle (2013): 2x78 MWth
  - DALKIA Trebovice (2015): 1x160 MW
  - SOLVAY Tavaux (2016): 1x134 MWth



- Limestone / Lime scrubbing system
  - ALBIOMA Le Moule (2012): 1 x 38 MWeI
  - CEH Paroseni (2015): 1 x 150 MWeI
  - ALBIOMA Le Gol (2016): 1 x 58 MWeI



- Sea water scrubber
  - LOKALSTYRE Longyearbyen (Spitzberg) - 2015

- **Biomass AVA Lisbjerg (DK)**
  - 1 line 110 MWth (137'000 Nm<sup>3</sup>/h)
  - Straw fire boiler
  - Dry system + SCR deNO<sub>x</sub> + flue gas condensation combined to combustion air humidification



## - Biomass Vattenfall Fynsvaerket Odense (DK)

- Existing Straw fire boiler 117 MWth equipped with SCR unit between BHF and condensation - Levy 3.35€/kg NO<sub>x</sub>
- **NO<sub>x</sub> guarantee : 15 mg/Nm<sup>3</sup> with NH<sub>3</sub> slip lower than 2 mg/Nm<sup>3</sup>**

# COPENHAGEN (DK) by 2025: 1<sup>st</sup> CO<sub>2</sub>-neutral capital & 100% renewable and recovery heat in District Heating! (98% of city's demand!)



by BIG Architects

Copenhill



250MWth Waste to Energy  
with flue gas condensation  
& absorption heat pumps



by Gottlieb Paludan Architects

BIO4 “Plant power”



500 MWth Wood Boiler  
with flue gas condensation

# Lab guarantees Flue Gas emissions compliant to the most stringent standards of the European Best Available Techniques



**Kara Noveren, Denmark**