Umwelt 
Bundesamt

For our Environment

11th annual meeting of the Task Force on Technoeconomic issues

# Emissions of natural-gas and fuel-oil fired medium combustion plants in Germany

Stockholm, 08.10.2025 by Anja Nowack

#### **Agenda**

- 1. CONTENT AND BACKGROUND OF THE PROJECT
- 2. MEASUREMENT RESULTS
- 3. BEST AVAILABLE TECHNIQUES
- 4. REGULATIONS IN 6 EUROPEAN COUNTRIES
- **5. EMISSIONS PROGNOSIS FOR GERMANY 2030**

#### Content and background of the project

#### **Content of the project**

- 100 emission measurements at medium combustion plants (MCPs): NO<sub>x</sub>, CO, dust, TOC, methane, smoke number
  - 78 for natural gas combustion, 28 for light fuel oil combustion
  - partly at dual fuel burners
  - rated thermal input 1-10 MW
  - Focus on existing plants (only 5 new plants)
- Calculation of emission factors (for emissions reporting)
- Calculation of the total emissions in Germany 2020
- Emissions prognosis for 2030
- Determination of best available techniques (BAT)
- Evaluation of regulations in 6 European countries

#### Content and background of the project

### Situation in Germany before the entry into force of the Medium Combustion Plants Directive (MCPD)

Natural-gas and light fuel-oil fired MCPs of 1 to 10 MW did not need a licence.

No regular NO<sub>x</sub> measurements obligatory

NO<sub>x</sub> emission limit values (ELV) only at test stand

CO ELV for safety reasons, having nothing to do with BAT

CO (and smoke number) measurements every 2 years by chimney sweepers

→ Very few measurement results available

#### Content and background of the project

#### Situation in Germany after the implementation of the MCPD

Regular NO<sub>x</sub> measurements every 3 years


- for existing plants beginning in 2025,
- for new plants beginning with the start of operation.

#### New ELVs for NO<sub>x</sub> and CO

Fuel	Plant type	NOx [mg/Nm³]	CO [mg/Nm³]	Smoke number	Exhaust gas heat loss
Natural gas	New plants	100	80	-	9 %
	Existing plants	150	110	-	9 %
Fuel oil	New plants	200	80	1	9 %
	Existing plants	200	150	1	9 %

#### Measurement results – fuel oil combustion - NO<sub>x</sub>

Nitrogen oxides measured values - fuel oil plants (standardised, 3 % reference oxygen content, average of three measurements, usually 30 minutes each)




Measurements existing installations

- Limit of quantification (6 mg/m³)
- Measurements existing installations with low NOx burners

Existing installations started operation before 20 december 2018.


#### Measurement results – natural gas combustion - NO<sub>x</sub>

Nitrogen oxides measured values – natural gas plants (standardised, 3 % reference oxygen content, average of three measurements, usually 30 minutes each)




#### Measurement results - fuel oil combustion - CO

Carbon monoxide measured values - fuel oil plants (standardised, 3 % reference oxygen content, average of three measurements, usually 30 minutes each)




#### Measurement results – natural gas combustion - CO

Carbon monoxide measured values – natural gas plants (standardised, 3 % reference oxygen content, average of three measurements, usually 30 minutes each)



#### Measurement results - natural gas combustion - methane

Methane measured values – natural gas plants (standardised, 3 % reference oxygen content, average of three measurements, usually 30 minutes each)



Existing plants started operation before 20 December 2018

#### **Summary of important measurement results**

#### NO<sub>x</sub> emissions

Fuel oil: 82 % of the measured values are below the MCPD ELV.

Natural gas: All new plants comply with the MCPD ELV.

98 % of the measured values for existing plants are below the MCPD ELV.

But: 21 % of the measured values are higher than the national ELV.

#### **CO** emissions

Fuel oil: CO < 40 mg/m<sup>3</sup> in all cases

<u>Natural gas</u>: 2 outliers with very high CO emissions → lack of maintenance?

All other boilers: < 40 mg/m<sup>3</sup>

#### **Methane emissions**

<u>Fuel oil</u>: < 3 mg/m<sup>3</sup> in all cases, 79 % below limit of quantification (LoQ)

Natural gas: 2 outliers with very high emissions (the same as for CO emissions)

All other boilers: < 4 mg/m<sup>3</sup>

#### **Summary of important measurement results**

#### **Dust emissions**

Fuel oil: ≤ 3 mg/m<sup>3</sup>

Natural gas: < 3 mg/m<sup>3</sup>

#### **TOC** emissions

Fuel oil: < 3 mg/m<sup>3</sup> in all cases

Natural gas: 2 outliers with very high TOC emissions

All other boilers: < 4.5 mg/m<sup>3</sup>

#### Smoke number

<u>Fuel oil:</u> < 1.6

#### Emission reduction techniques for gas- and oil-fired burners

Pollutant technique	NO <sub>x</sub>	SO <sub>2</sub>	со	тос	NMVOC	Dust	Energy efficiency
Waste gas heat utilisation	x	-	х	х	х	х	х
Lambda sensor/O <sub>2</sub> control	х	-	х	х	х	х	х
Low-sulphur fuels	х	х	-	-	-	-	-
Exhaust gas recirculation (external)	х	-	x	х	х	х	х
Exhaust gas recirculation (internal)	х	-	х	х	х	х	х
Low NO <sub>x</sub> burner	х	-	-	-	-	-	-
Non-catalytic reduction (SNCR)	х	-	-	-	-	-	-
Catalytic reduction (SCR)	х	-	-	-	-	-	-

#### Flue-gas heat utilization

Condensing boilers are only used with some new plants.

#### Lambda sensor/O<sub>2</sub> control

Generally applicable, also as a retrofit

#### Low-sulphur, low-nitrogen fuel

Low-sulphur fuel oil is widely available, some old peak-load plants may still use old stocks.

DIN (national) standard 51603-1 defines "Extra light (EL) fuel oil low sulphur, low nitrogen":

≤ 140 mg N per kg fuel

#### **Exhaust gas recirculation (EGR)**

External: outside the combustion chamber

Internal: inside the combustion chamber or the burner

Retrofit only possible for external EGR

#### Low NO<sub>x</sub> burner

Generally applicable, also as a retrofit

Principle: Lowering the temperature in the "flame root" and exhaust gas recirculation

Low NO<sub>x</sub> burners can generally be used except for reverse flame boilers.

Retrofit possible with some exceptions

Difficulties can arise because the low NO<sub>x</sub> burner generally has a lower output than a standard burner installed in the same boiler due to the reduced flame temperature. If the output leads to an undersupply of the connected heat users, the burner may not be fit for purpose.

#### Selective non-catalytic reduction (SNCR)

Injection of urea or NH<sub>3</sub> into the exhaust gas

Temperature window 900-1050 °C (may not be achieved at part load)

In Germany only used for heavy fuel oil boilers

#### **Selective catalytic reduction (SCR)**

Catalyst that selectively reduces nitrogen oxides to inert nitrogen  $(N_2)$ .

Exhaust gas temperature of at least around 350 °C for the reaction.

Generally applicable, also as a retrofit, but expensive → in DE not used for boilers as MCPs

#### Regulations in European countries

#### Workshop with presentations from AT, BE, DK, DE, NL,CH

Direct comparison of ELVs not possible, differences:

- Addition/subtraction/no consideration of measurement uncertainty
- Measurement duration (30 to 90 minutes)
- Compliance with ELV of all measured values/average of measured values
- Measurement periods: every 3 months every 3 years


#### Nationally used techniques

Low NO<sub>x</sub> burners are BAT in the 6 participating countries:

- In AT, BE (Flanders), NL also for existing plants
- In DE only for new plants

NL has the strictest regulation: ELV of 70 mg/m $^3$  NO $_x$ – which implies obligatory use of low-NO $_x$  burners - for new and existing plants.

#### **Emissions prognosis for Germany 2030**



Note: Methane, dust with "<" as measurement results were partly below the limit of quantification (LOQ) and used for the emis sion factor with half the LOQ.

Scenario 1: with German ELVs, scenario 2: with Dutch NO<sub>x</sub> ELV

## Umwelt **1** Bundesamt

## Thank you for your attention!

#### For further information

anja.nowack@uba.de

https://www.umweltbundesamt.de/publikationen/determinat ion-of-emission-factors-emissions-in-2020

